



# *Town of Mattapoisett*

*Massachusetts 02739*

*Tel: 508-758-4161*

*Fax: 508-758-4162*

## *Water and Sewer Department*

*19 County Road*

*P.O. Box 474*

### **TOWN OF MATTAPOISETT WATER DEPARTMENT**

#### **TO THE CUSTOMERS OF THE MATTAPOISETT WATER DEPARTMENT**

The Mattapoisett Water Department has produced its Annual Water Quality Report. This report identifies the source of Mattapoisett's drinking water, the results of water quality monitoring in 2010 and health related information important to all consumers regardless of the source of their drinking water. If you have not received a copy of the Water Quality Report, one can be obtained by calling the Mattapoisett Water Department at 508-578-4161, Monday through Friday between the hours of 8:00 a.m. and 4:00 p.m.

# MATTAPOISETT WATER DEPARTMENT

## PUBLIC WATER SYSTEM ID#4173000

### 2010 DRINKING WATER QUALITY REPORT

This is the annual water quality report of the Mattapoisett Water Department. This report is intended to provide you with important information about your drinking water. We know that you count on us for a safe and reliable supply of water every day and our goal is to provide the highest quality of service to you.

**We want you, our customers to know that our drinking water is safe and meets Federal and State standards.**

#### **YOUR DRINKING WATER SOURCE**

All of the drinking water supplied to our customers is provided by ground water from four (4) municipal wells in the Mattapoisett River Valley Aquifer. The four wells are made up of the following:

- #2 Station-Well Field, located off Acushnet Road.
- #3 Station-Gravel Packed Well, located off Hereford Hill Road.
- #4 Station-Gravel Packed Well, located off Hereford Hill Road.
- #5 Station-Gravel Packed Well, located on Pumping Station Road, off Long Plain Road. Currently the average daily demand is 520,608 gallons per day, with a peak demand of 1,213,000 gallons per day. The wells are all within the Department of Environmental Protection Approved Mattapoisett River Aquifer Protection District and they are located in the northwestern part of town. Our department also owns the areas around the wells and restricts any activity that could contaminate them.

Mattapoisett also receives water from the Mattapoisett River Valley Water District Public Water Supply # 4173001. The District gets water from five additional groundwater wells in the Mattapoisett River Valley Aquifer.

#### **WHAT CAN BE IN DRINKING WATER?**

All sources of drinking water (both tap water and bottled water) including rivers, lakes, streams,

ponds, reservoirs, springs and wells are subject to potential contamination that are naturally occurring or are man made. Contaminants that can potentially be present in source water include:

**Microbial Contaminants** such as viruses and bacteria may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Organic Chemical Contaminants** include synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can come from gas stations, urban storm water runoff and septic systems.

**Inorganic Contaminants** such as salts and metals can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, and farming.

**Pesticides and Herbicides** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Radioactive Contaminants** can be naturally occurring or be the result of oil and gas production, and mining activities.

**Unregulated Contaminants** are those for which E.P.A. has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist E.P.A. in determining their occurrence in drinking water and whether future regulation is warranted.

**Health Information** In order to ensure that tap water is safe to drink the E.P.A. prescribes regulations that limit the amount of certain contaminants in the water provided by public water systems. All drinking water including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (1-800-426-4791). Their regulations are set at very stringent levels. Some people may be more vulnerable to contaminants in drinking water than the general population. Immune compromised persons such as

persons with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and some infants can be particularly at risk from infection. These people should seek advice about drinking water from their healthcare providers. E.P.A./Center for Disease Control guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other

microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791)

## ROUTINE WATER QUALITY MONITORING

To ensure that your water is safe, regular monitoring and testing of water quality is conducted by our State licensed operators and analyzed in State Certified laboratories.

### WATER QUALITY DATA

This table shows results of monitoring for the period of January 1 to December 31, 2010

Contaminant	MCL	MCLG	Highest Level Detected	Range of Detection	Sources of Contaminant	Violation
Inorganic Chemicals						
Sodium (ppm)	NR	NR	35.4	25.7-35.4	Natural occurring salt deposits. Saltwater intrusion	No
Chloroform (ppb)	NR	NR	1.5	1.4-1.5	Naturally occurring	No
Sulfate (ppm)	NR	NR	11.0	nd-11.0	Erosions of natural deposits	No No
Nitrate (ppm)	10	10	0.61	< 0.10-0.61	Runoff from fertilizer use: leaching from septic tanks, sewerage, erosion of natural deposits.	
Radioactive Contaminants						
Gross Alpha	15	0	0.6(+or-1.1)	0.0-0.6	Erosion of natural deposits	No
Radium 226	5	0	0.3(+or-0.3)	0.0-0.3		
228	5	0	0.8(+or-0.9)	0.0-0.8	Erosion of natural deposits	No
(pCi/l)						
Beta particles*	4	0	1.1(+or-2.5)			
Perchlorate(ppb)	2	NA	0.16	0.06-0.16	Rocket propellants, Fireworks, Munitions	No
Lead (ppb)	AL=15	0	4 No locations exceeded the AL	1-4 90%=4	Corrosion of household plumbing systems. Erosion of natural deposits.	No
Copper (ppm)	AL=1.3	1.3	0.66 No locations exceeded the	0.05-0.66 90%=0.45	Corrosion of household plumbing systems, leaching from wood	No

\*Monitoring data from 2003-As authorized and approved by E.P.A. the state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

The previous table shows only the substances that were detected in the Mattapoissett Drinking water. Additional testing for 56 volatile organic chemicals and 13 inorganic chemicals showed no detection of any of those chemicals.

Our system had no violations of water quality for the 2010 reporting period.

*“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Mattapoissett water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”*

For a complete listing of all the possible contaminants that we are required to test for contact our Water Superintendent.

If you have any questions about this report please contact William T. Nicholson, Superintendent at (508)-758-4161.

The Mattapoissett Water Department is operated under the direction of the Board of Water Commissioners. Their meetings are held at 6:00 p.m. on the second and last Wednesday of each month in the Water Department Office at 19 County Road.

### **Summer water saving tips**

You can have a beautiful garden and lawn and still save a great deal of water by following these water saving tips.

- Water your garden and lawn only when it needs it rather than on a regular schedule.
- Water during cooler parts of the day to reduce the amount of evaporation.
- Don't water the driveway or street, align your sprinkler so the water falls on your lawn or garden not the paved surfaces.
- Know how to turn off your automatic sprinkler if it rains.
- Don't leave your hose unattended, it can pour out hundreds of gallons in just a few hours.
- Use mulch around trees and plants to minimize moisture loss while also discouraging weeds.
- Fix any leaks on toilets, hoses and faucets as soon as possible.

### **Source Water Assessment and Protection (SWAP)**

The source water assessment and protection program assesses the susceptibility of the public water supplies to potential contamination by microbiological pathogens and chemicals. A susceptibility ranking of high was assigned to this system using the information collected during the assessment by the DEP. The complete SWAP report is available at the Water and Sewer Department at 19 County Road.

This can also be accessed at the DEP website at [www.mass.gov/dep/water/drinking/sourcewa.htm](http://www.mass.gov/dep/water/drinking/sourcewa.htm)

**For additional water saving facts and ideas please contact or stop by our office at 19 County Road for more information.**

### **TERMS AND ABBREVIATIONS**

**MAXIMUM CONTAMINATION LEVEL OR MCL:** The highest level of a contaminate allowed in drinking water. MCLs are set as close to the MCLGs (see below) as feasible using the best available treatment technology.

**MAXIMUM CONTAMINATION LEVEL GOAL OR MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**ACTION LEVEL:** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements, which a water system must follow.

**TREATMENT TECHNIQUE (T.T.):** A required process intended to reduce the level of a contaminant in drinking water.

**ppm:** Parts per Million or Milligrams per liter (mg/l)

**ppb:** Parts per Billion or Micrograms per liter (ug/l)

**NR:** Not regulated

**ND:** Non-Detectable at Testing Limit

**pCi/l:** Picocuries per liter (a measure of radiation)

MATTAPoisETT WATER & SEWER  
19 COUNTY ROAD  
P.O. BOX 474  
MATTAPoisETT, MA 02739

Presorted Standard  
U.S. Postage Paid  
Mattapoisett, MA  
Permit No. 13